

Cushing Village Special Permit
Condition 3.A (i) Part III

From: [Clancy, Glenn](#)
To: [Clancy, Glenn](#)
Subject: FW: Acentech Review of Cushing Village Development Sound - Report Two
Date: Wednesday, July 15, 2015 1:31:33 PM

From: Clancy, Glenn [mailto:gclancy@belmont-ma.gov]
Sent: Thursday, October 16, 2014 4:01 PM
To: Wood, Eric W.
Cc: Yogurtian, Ara; Wheeler, Jeffrey
Subject: RE: Acentech Review of Cushing Village Development Sound - Report Two

Hi Eric:

I spoke with Jeffrey and he has confirmed that the developer has it right.

“sound from Cushing Village to not increase by more than 5 dBA the average of the background L90 sound levels that have been measured during a) daytime periods 7:00 AM to 11:00 PM and b) during nighttime periods 11:00 PM to 7:00 AM.”

Thanks, Glenn Clancy

From: Wood, Eric W. [mailto:ewood@ACENTECH.com]
Sent: Monday, October 13, 2014 3:35 PM
To: Yogurtian, Ara; Clancy, Glenn
Subject: Acentech Review of Cushing Village Development Sound - Report Two

Ara and Glenn,

Attached is Acentech’s report providing the results of our review of the updated information for Cushing Village Development received from Cavanaugh Tocci Associates for the developer.

Let me know if you have any questions or need additional information.

Eric

Acentech