

# Perkins&Will

## PENDING DOCUMENT REVISIONS LOG

Belmont Middle and High School

1/11/2022

### → NEW ITEM SINCE LOG DATED 1/3/22

PENDING REVISIONS				
ID	To Issue	OME	Subject	Description
ASI-033	2/1/2022	\$0	POOL & FIELD HOUSE BANNER SYSTEM DETAILS	Clarifications to banner support system.
ASI-215	1/14/2022	\$0	MISC. WALL DEVICES CLARIFICATIONS	Miscellaneous coordination of wall device locations including: Stair 6 per RFI 1426, EX04 exterior light fixture locations at Area F west, darkroom light, and misc. coordinations throughout general classrooms.
ASI-217	1/14/2022	\$0	BUILDING GRAPHICS ARTWORK	Provide final artwork for building wall and gym floor graphics.
PR-091 AMENDED	1/14/2022	\$50,000	ART WING VENTILATION	Provide enhanced clay particle filtration in Art Rooms.
→ PR-101 AMENDED	1/14/2022	\$46,000	VIDEO PRODUCTION OWNER REVISIONS - ADDITIONAL DETAIL FOR PRICING	Providing additional info. at Skanska's request to more accurately price what was originally proposed in PR-101.
PR-111	TBD	\$1,000	LOCKS FOR AUD. CONTROL ROOM SLIDING WINDOWS	PW researching options to provide locking mechanism for (2) sliding glass panels at the auditorium control room, per direction from Bill Lovallo during 11/18/21 walkthrough.
PR-123	TBD	\$30,000	PERMANENT DARKROOM & PHOTOGRAPHY ROOM REVISIONS	Proposed revisions to the permanent darkroom following temp. darkroom experiences: - Red light quantity and brightness. - Clear spacing and height of dividers. - Upgraded exhaust system in Photography Room
PR-124	1/14/2022	\$20,000	CONCORD & GODEN ROADWAY DRAINAGE - SCHEMATIC DESIGN PROPOSAL	PR-124 provides a schematic design proposal to add a catch basin and modify roadway grading at Concord & Goden streets to address ponding.
PR-125	TBD	\$20,000	AUDITORIUM BALCONY RAIL	PR-125 proposes an additional handrail along the leading edge of the auditorium balcony seating area as well as a proposed revision to the slope of the millwork cap.
PR-126	TBD	\$20,000	MILLWORK CAP REVISIONS	PR-126 proposes a sloped in lieu of flat millwork cap along the leading edge of the auditorium balcony.
PR-127	2/4/2022	\$4,000	MS MOBILE TRASH CABINETS REVISIONS	This Directive revises the detailing of the mobile trash cabinets to provide more strength and rigidity to the units. Note: Option to eliminate and replace with Furniture as cost effective solution
PR-128	1/21/2022	\$7,500	ADD EXTERIOR LADDER TO ACCESS FIELD HOUSE ROOF	Adding exterior ladder south of existing small gym to access Field House roof.
PR-129	1/14/2022	\$7,500	STAIR 10 HANDRAIL	Adding code-required permanent handrail to stair 10, which is the small stair leading to the stage from the main auditorium audience level.
CCD-334	1/14/2022	\$2,500	ROOM NUMBER CHANGES	Modify room numbers in (5) rooms in Phase 1 and (6) rooms in Phase 2 to facilitate signage by having room prefix to be the same as adjacent rooms.

# Perkins&Will

## PENDING DOCUMENT REVISIONS LOG

Belmont Middle and High School

1/11/2022

CCD-369	2/1/2022	SEE PR-124	CONCORD & GODEN ROADWAY DRAINAGE - PERMANENT DESIGN	Additional drainage and/or grading revisions to southeast corner of Concord & Goden Sts. due to ponding in moderate to heavy rains.
CCD-386	TBD	\$15,000	PHASE 1 SECURITY CAMERA OBSTRUCTIONS	Relocating ceiling devices to permit clear lines of sight for several obstructed security cameras in Phase 1.
CCD-400	1/14/2022	\$20,000	TEMP. DARKROOM EXHAUST	CCD-400 provides exterior wall exhaust for the temp. darkroom in lieu of roof-mounted exhaust. Also included is localized exhaust for the work counter in the temp. photography room.
CCD-401	TBD	\$1,000	AUDIBLE FIRE ALARM SIGNAL AT OFFICE B332	Modifying fire alarm devices at Office B332 to ensure audible signal meets required dB levels.
Subtotal Pending Rev.		\$244,500		